



A P P R O V A L S ®

## Certificate of Approval

**Certificate No.:** SAA-181590-EA

**Certificate Holder:** Sparkelec Pty Ltd  
56 Parramatta Rd  
Croydon NSW 2132  
Australia

**Class Description:** Residual Current Device  
**Product Description:** Residual Current Operated Circuit Breaker  
**Brand Name:** SPARKELEC  
**Model No.:** DL7NL-40 series  
**Markings:**  $U_e=240V \sim 50/60Hz (1P+N)$   
 $I_n=6, 10, 16, 20, 25, 32, 40A$  Type B and C  
 $I_{\Delta n}=0.01$  Type 1, 0.03, 0.1A Type A and AC  
 $I_{\Delta m}=500A$   
 $I_{cn}=I_{cs}=6000A$  or 4500A ( $I_n=6-25A$ ), 4500A ( $I_n=32-40A$ )  
**Standard:** AS/NZS 61009.1:2015  
**Conditions:** Nil  
**Approval Mark:** SAA-181590-EA or RCM  
**Date First Registered:** 25 June 2018  
**Date of Expiry:** 25 June 2023


For and on Behalf of  
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:  
[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 25-06-18 181590/1