

Our Ref: VEW/17/134

27 November 2019

Sparkelec Pty Ltd / AGM Electrical Supplies Pty Ltd  
3/52-54 Parramatta Rd,  
CROYDON NSW 2132

Dear Mr. Lu

**CONFIRMATION OF COMPLIANCE TO ESV'S ADDITIONAL REQUIREMENTS FOR RCBOs**

Thank you for your submission of the documentation and samples of your RCBOs.

The submitted samples and documents have been reviewed and it has been confirmed that they pass the additional requirements set out by Energy Safe Victoria (ESV) for RCBOs on 3 July 2019.

The following details will be added to the list of complying products on ESV's website:

Brand	Model	Rating	Construction
DL	DRNL-32	C6, C10, C16, C20; 30mA; 3kA; Type AC	2 pole device, 18mm wide, directionally marked
DL	DRNL/4PRCBO	6A, 10A, 16A, 20A, 25A, 32A, 40A; B or C curve; 30mA; 6kA; Type A or AC	4 pole device, 72mm wide, non-directional
Sparkelec	DRNL/4PRCBO	6A, 10A, 16A, 20A, 25A, 32A, 40A; B and C curve; 30mA; 6kA; Type A or AC	4 pole device, 72mm wide, non-directional

This letter is not a product endorsement; it is confirmation that the submitted samples pass the additional testing as set out by ESV. This letter is not a confirmation that the above listed products meet all requirements of the Electricity Safety Act 1998.

Thank you for your submission and cooperation in this regard.

If you have further enquiries, please contact Gergo Bogdan, Safety Compliance Engineer on telephone (03) 9203 9760 or by email [gergo.bogdan@energysafe.vic.gov.au](mailto:gergo.bogdan@energysafe.vic.gov.au).

Yours sincerely



Goran Sokoleski  
**SENIOR ENGINEER - MARKET INTELLIGENCE & ENFORCEMENT**