



A P P R O V A L S ®

Certificate of Suitability

Certificate No.: SAA170227

Certificate Holder: Sparkelec Pty Ltd
Suite 4B, Level 4 Redmyre House,
9-13 Redmyre Road
Strathfield NSW 2135
Australia

Class Description: Non-Declared
Product Description: LED Emergency Lighting (Exit Sign)

Brand Name:  SPARKELEC
Model No.: SP-2001-xx-MHyyy series
Markings: Charging mode:-
220-240V ~ 50/60Hz Max 3W
Emergency lighting mode:-
Battery: 4.8V 1W, 10/20 Im;
Ni-MH Battery: 4.8Vdc 800/1200mAh
Maintained, 2 or 3 hours emergency duration,
ta:40°C, IP20, Class II

Standard: AS/NZS 60598.2.22:2005
AS/NZS 60598.1:2013

Conditions: Nil

Certification Mark: SAA170227 or RCM

Date First Registered: 6 April 2017

Date of Expiry: 6 April 2022


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 06-04-17 170227/1