

CB TEST CERTIFICATE CERTIFICAT D'ESSAI OC

Product
ProduitName and address of the applicant
Nom et adresse du demandeurName and address of the manufacturer
Nom et adresse du fabricantName and address of the factory
Nom et adresse de l'usineNote: When more than one factory, please report on page 2
Note: Lorsque il y plus d'une usine, veuillez utiliser la deuxième pageRatings and principal characteristics
Valeurs nominales et caractéristiques principalesTrademark (if any)
Marque de fabrique (si elle existe)Type of Manufacturer's Testing Laboratories used
Type de programme du laboratoire d'essais constructeur
Model / Type Ref.
Ref. De typeAdditional information (if necessary may also be reported on page 2)
Les informations complémentaires (si nécessaire, peuvent être indiqués sur la deuxième pageA sample of the product was tested and found to be in conformity with
Un échantillon de ce produit a été essayé et a été considéré conforme à laAs shown in the Test Report Ref. No. which forms part of this Certificate
Comme indiqué dans le Rapport de tests numéro de référence qui constitue partie de ce CertificatThis CB Test Certificate is issued by the National Certification Body
Ce Certificat de test OC est établi par l'Organisme National de Certification

LED lighting lamps and lanterns with emergency lighting

SPARKELEC PTY LTD
56 Parramatta Rd Croydon NSW 2132
Sydney
AustraliaSPARKELEC PTY LTD
56 Parramatta Rd Croydon NSW 2132
Sydney
Australia

REMOVED

☐ Additional information on page 2Charging mode: 220-240 VAC, 50/60 Hz, 4 W.
Emergency lighting mode: LiFePO4 battery, 3.2 V d.c., 1500 mAh.
Class II

SPxxxxyy-zz

IP20, ta: 25 °C - +40 °C, Maintained, 3 hours duration. The 'xxxx' in the type designation can be 2001, 2002, 2003, indicating different enclosure. The 'yy' can be DA or FE, indicating different function. The 'zz' can be WH or BK, indicating different enclosure / exit signs colour. See test report for model explanation.

☐ Additional information on page 2IEC 60598-1:2014, IEC 60598-1:2014/AMD1:2017
IEC 60598-2-22:2014, IEC 60598-2-22:2014/AMD1:2017

423896

Philip Pedersens vei 11,
NO-1366 Lysaker, Norway

Date: 10-05-2022

Yasaman Vadoudi

Signature: Yasaman Vadoudi
Certification Department