



A P P R O V A L S ®

## Certificate of Suitability

**Certificate No.:** SAA162502

**Certificate Holder:** Sparkelec Pty Ltd  
Suite 4B, Level 4 Redmyre House,  
9-13 Redmyre Road  
Strathfield NSW 2135  
Australia

**Class Description:** Non-Declared  
**Product Description:** LED Emergency Lighting

**Brand Name:**  SPARKELEC  
**Model No.:** SP-20xx-yyzzz Series  
**Markings:** Charging mode: 220-240V~ 50/60Hz, Max 2.5W  
Emergency lighting mode: 4.8Vdc 1W 40lm  
Battery: 4.8Vdc, 300/600/800mAh NiMH/NiCd  
ta:40°C, Class II, IC  
**Standard:** AS/NZS 60598.2.22:2005  
AS/NZS 60598.1:2013

**Conditions:** Nil

**Certification Mark:** SAA162502 or RCM

**Date First Registered:** 29 November 2016  
**Date of Expiry:** 29 November 2021




For and on Behalf of  
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:  
[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 29-11-16 162502/1