



A P P R O V A L S ®

Certificate of Suitability

* Addendum *

Certificate No.: SAA162502

Date of Issue: 29 November 2016

Class Description: Non-Declared

Product Description: LED Emergency Lighting

General Modification:

For SP-20xx-yyzzz Series:

'xx' denotes type of mounting and can be '02' for recessed or '03' for ceiling;

'yy' denotes battery type and can be 'CD' for Ni-Cd or 'MH' for Ni-MH; and

'zzz' denotes rated emergency duration in minutes and can be '060', '120' or '180'.

A handwritten signature in black ink, appearing to be 'JH', positioned above a horizontal line.


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 29-11-16 162502/2