

A sample of the following product has been tested and is stated by Nemko to be in conformity with the applicable European standards referred below.

Product	LED emergency lighting (exit sign)
Manufacturer	SPARKELEC PTY LTD 56 Parramatta Rd Croydon NSW 2132, Sydney Australia
Factory	Jinyi (Zhongshan China) Lighting Co., Ltd Qi Fang Industrial District, Tong Yi Industrial Zone, Guzhen Town, Zhongshan City, Guangdong Province China
Ratings	Charging mode: Max.2.5 W 220-240 V 50/60 Hz. Emergency lighting mode: 4.8 V battery, 1 W, 40lm. Battery supply: 300 / 600 / 800 mAh, 4.8 V d.c. Ni-MH / Ni-Cd.
Trade mark	
Model / Type Ref.	SP-20xx-yyzzz series
Principal characteristics	Cl. II, IP20, ta 0 - +40 oC, Maintained, 1 / 2 / 3 hours duration. With integral LED module, with integral LED driver.
A sample of the product was tested and found to be in conformity with	LITE EN 60598-2-22:2014 EN 60598-1:2015 EMF EN 62493:2015 EMC EN 55015:2013;A1 EN 61547:2009 EN 61000-3-2:2014 EN 61000-3-3:2013

Test Report Ref. No. **CONFIDENTIAL INFORMATION WITHDRAWN**

It may therefore be presumed that the tested sample of the product is in conformity with the technical provisions of the following European Directives including the latest amendments, and with national legislation implementing these Directives:

- Low Voltage Directive 2014/35/EU
- EMC Directive 2014/30/EU

Provided that other applicable Directive requirements are satisfied, the manufacturer (or the European authorized representative), may draw up an EC/EEA Declaration of Conformity and affix the CE-marking to each conforming product.

Additional model(s)

Additional information

The "xx" in the type designation can be 02 or 03, indicating the mounted type of luminaire, see attachment 10 xx = 03: ceiling mounted; xx = 02: recessed mounted

The "yy" can be CD or MH, indicating the battery type. yy = CD: Ni-Cd battery; yy = MH: Ni-MH battery

The "zzz" can be 060, 120 or 180, indicating the rated emergency duration in minute. zzz = 060: 60 minutes; zzz = 120: 120 minutes; zzz = 180: 180 minutes

Date of issue 10-11-2016



Okhyun Jeon
Certification Department