



A P P R O V A L S ®

Certificate of Conformity

Certificate No.: SAA-192900-EA

Certificate Holder: Sparkelec Pty Ltd
56 Parramatta Rd
Croydon NSW 2132
Australia

Class Description: Residual Current Device
Product Description: RCBO (Residual current circuit breaker with integral overcurrent protection)

Trade Name: DL

Model No.: DRNL/4PRCBO

Markings: Ue: 415Vac (3P+N), 50/60Hz

In: 6, 10, 16, 20, 25, 32, 40A Type B and C

IΔn: 30mA, 100mA, 300mA Type A and AC

Icn=Ics: 6kA

IΔm: 3kA

Standard: AS/NZS 61009.1:2015

Conditions: Nil

Approval Mark: RCM and SAA-192900-EA

Date First Registered: 16 October 2019

Date of Expiry: 16 October 2024

R.A. Hill


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 21-10-19 192900/1a
Markings amended